Gardner

COMPRESSOR DATA SHEET

Federal Uniform Test Method for Certain Air Compressors Not Applicable Compressors Variable Frequency Drive

							OMPRE:							
1	Manufacturer: Gardner Denver													
	Model N	umber	TV	S250-A1	55 (NA-	-IP23)				Date:	Jı	me 2024		
2	X Air-cooled Water-cooled								Туре:		Screw			
	Oil Injected X Oil-Free								# of Stages:		2			
3*	Full Load	l Operati	ing Pressu	re ^b			100			psig ^b				
4	Drive Motor Nominal Rating								335			hp		
5	Drive Motor Nominal Efficiency							95.6%			percent			
6	Fan Motor Nominal Rating (if applicable)							20.1			hp			
7	Fan Motor Nominal Efficiency							92.1%			percent			
	Input Power (kW)							Capac	Capacity (acfm) a,d		Specific Power (kW/10 acfm) ^d		W/100	
	267.5 Max								1493		17.92			
	225.3								1295		17.40			
8*	186.6							1089		17.14				
	151.2								877			17.23		
	118.4								660 1		17.94			
	87.8 Min							1	438 20.0		20.04			
9*	Total Package Input Power at Zero Flow ^{c, d}								0.0		kW			
10	Specific Power (kW/100ACFM)	85.00 80.00	200	400	600	800 Cap	1000 acity (ACI		1400	1600	1800	2000		

^{*} For models that are tested in the CAGI Performance verification Program, these items are verified by program administrator and the CAGI Performance verification of the program administrator and the program administration administration and the program administration and the program administration administration and the program administration administration and the program administration administration administration administration a

Consult CAGI website for a list of participants in the third party verification program:

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
 - b. The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet.
 - c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1% manufacturer may state "not significant" or "0" on the test report.
 - d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document

10 12: The terms power and energy are synonymous for purposes of this document										
Volume : at specified	flow rate I conditions	Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power						
m ³ /min	ft ³ /min	%	%							
Below 0.5	Below 17.6	+/-7	+/-8							
0.5 to 1.5	17.6 to 53	+/-6	+/-7	+/- 10%						
1.5 to 15	53 to 529.7	+/-5	+/-6							
Above 15	Above 529.7	+/-4	+/-5							

Member

ROT 031.2

12/19 R3

This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data