Gardner

COMPRESSOR DATA SHEET

Federal Uniform Test Method for Certain Air Compressors Not Applicable Compressor: Variable Frequency Drive

	Rotary Compressor: Variable F MODEL DATA - FOR COMP		
1	Manufacturer: Gardner Denver		
	Model Number TVS250-W155 (NA-IP23)	Date: June 202	24
2	Air-cooled X Water-cooled	Type: Screw	
	Oil Injected X Oil-Free	# of Stages: 2	
3*	Full Load Operating Pressure ^b	125 psig ^b	
4	Drive Motor Nominal Rating	335 hp	
5	Drive Motor Nominal Efficiency	95.6% percent	ţ
6	Fan Motor Nominal Rating (if applicable)	2.4 hp	
7	Fan Motor Nominal Efficiency	82.5% percent	į
	Input Power (kW)	Capacity (acfm) a,d Specific Power acfm) acfm)	
	271.8	Max 1451 18.73	
	233.2	1262 18.47	
8*	197.0	1067 18.46	
	163.1	867 18.82	
	130.9	661 19.80	
	100.3	Min 451 22.21	
9*	Total Package Input Power at Zero Flow ^{c, d}	0.0 kW	
	35.00		_
	30.00		_
	A CFM		_
10	25.00 (KW/1004 CF/M) 20.00 (Specific Power 20.00)		_
	15.00		_
	10.00 0 200 400 600 800 100	0 1200 1400 1600 1800 2000	_ 0
	Capacity	ACFM)	
	Note: Graph is only a visual represent Note: Y-axis scale 10 to 35, +5kW/100acfm X-Axis Scale, 0 to 25% over	increments if necessary above 35	

^{*} For models that are tested in the CAGI Performance verification Program, these items are verified by program administrator

Consult CAGI website for a list of participants in the third party verification program:

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
 - $b. \ \ The operating \ pressure \ at \ which \ the \ Capacity \ and \ Electrical \ Consumption \ were \ measured \ for \ this \ data \ sheet.$
 - c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1% manufacturer may state "not significant" or "0" on the test report.
 - d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document

110 12. The terms power and energy are synonymous for purposes of any document							
	Volume flow rate at specified conditions		Specific Energy Consumption	No Load / Zero Flow Power			
m ³ /min	ft ³ /min	%	%				
Below 0.5	Below 17.6	+/-7	+/-8				
0.5 to 1.5	17.6 to 53	+/-6	+/-7	+/- 10%			
1.5 to 15	53 to 529.7	+/-5	+/-6				
Above 15	Above 529.7	+/-4	+/-5				

Member

ROT 031.2

12/19 R3 This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data