Part No. 47863404001 Rev A ECN 1511811

## Gardner Denver

## COMPRESSOR DATA SHEET

## Federal Uniform Test Method for Certain Air Compressors Not Applicable

**Rotary Compressor: Variable Frequency Drive** MODEL DATA - FOR COMPRESSED AIR Manufacturer: Gardner Denver 1 Model Number TVS250-W155 (NA-IP23) Date: June 2024 Water-cooled Air-cooled X Type 2 Screw X Oil-Free # of Stages Oil Injected 2 3\* Full Load Operating Pressure<sup>b</sup> 115 psig<sup>b</sup> 4 Drive Motor Nominal Rating 335 hp 5 Drive Motor Nominal Efficiency 95.6% percent 6 Fan Motor Nominal Rating (if applicable) 2.4 hp 7 Fan Motor Nominal Efficiency 82.5% percent Specific Power (kW/100 Capacity (acfm) a,d Input Power (kW) acfm) 271.2 1494 18.16 Max 231.2 1298 17.81 8\* 194.0 1095 17.71 159.2 886 17.97 126.6 672 18.84 95.6 Min 453 21.09 9\* 0.0 kWTotal Package Input Power at Zero Flow<sup>c, d</sup> 35.00 30.00 Specific Power (kW/100ACFM) 20.00 10 15.00 10.00 2000 200 400 600 800 1000 1200 1400 1600 1800 Capacity (ACFM)

\* For models that are tested in the CAGI Performance verification Program, these items are verified by program administrator

Consult CAGI website for a list of participants in the third party verification program:

www.cagi.org

DTES:

a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;

ACFM is actual cubic feet per minute at inlet conditions.

Note: Graph is only a visual representation of the data in section 8

Note: Y-axis scale 10 to 35, +5kW/100acfm increments if necessary above 35

X-Axis Scale, 0 to 25% over maximum capacity

- b. The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet.
- C. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1% manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document

TOTAL THE terms power and energy are symonymous for purposes of any document				
Volume flow rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
m <sup>3</sup> /min	ft <sup>3</sup> /min	%	%	
Below 0.5	Below 17.6	+/-7	+/-8	
0.5 to 1.5	17.6 to 53	+/-6	+/-7	+/- 10%
1.5 to 15	53 to 529.7	+/-5	+/-6	
Above 15	Above 529.7	+/-4	+/-5	

Member

ROT 031.2

12/19 R3 This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data