## Gardner

## COMPRESSOR DATA SHEET

## Federal Uniform Test Method for Certain Air Compressors Not Applicable Compressors Variable Frequency Drive

	MODEL DATA - FOR COMP					
1	Manufacturer: Gardner Denver					
2	Model Number TVS250-A155 (NA-IP55)	Date: June 2024				
	X Air-cooled Water-cooled	Type: Screw				
	Oil Injected X Oil-Free	# of Stages: 2				
3*	Full Load Operating Pressure <sup>b</sup>	115 psig <sup>b</sup>				
4	Drive Motor Nominal Rating	335 hp				
5	Drive Motor Nominal Efficiency	96.1% percent				
6	Fan Motor Nominal Rating (if applicable)	<b>20.1</b> hp				
7	Fan Motor Nominal Efficiency	<b>92.1%</b> percent				
	Input Power (kW)	Capacity (acfm) a,d Specific Power (kW/acfm) acfm) d				
	266.2	Max 1429 18.63				
	226.2	1241 18.23				
8*	189.6	1047 18.10				
	155.8	848 18.37				
	124.3	644 19.31				
	94.6	Min 435 21.73				
9*	Total Package Input Power at Zero Flow <sup>c, d</sup>	0.0 kW				
	35.00					
	30.00					
	25.00 CCEM)					
10	(KW/1004 CFM) 25.00 (SW/1004 CFM) 20.00					
	15.00					
	10.00 0 200 400 600 800 100					
	Capacity					
	Note: Graph is only a visual represent Note: Y-axis scale 10 to 35, +5kW/100acfm X-Axis Scale, 0 to 25% over	n increments if necessary above 35				

<sup>\*</sup> For models that are tested in the CAGI Performance verification Program, these items are verified by program administrator and the CAGI Performance verification of the program administrator and the program administration administration and the program administration and the program administration administration and the program administration administration and the program administration administration administration administration a

Consult CAGI website for a list of participants in the third party verification program:

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
  - b. The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet.
  - c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1% manufacturer may state "not significant" or "0" on the test report.
  - d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document

110 12. The terms power and energy are synonymous for purposes of any document						
Volume flow rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power		
m <sup>3</sup> /min	ft <sup>3</sup> /min	%	%			
Below 0.5	Below 17.6	+/-7	+/-8			
0.5 to 1.5	17.6 to 53	+/-6	+/-7	+/- 10%		
1.5 to 15	53 to 529.7	+/-5	+/-6			
Above 15	Above 529.7	+/-4	+/-5			

Member

ROT 031.2

12/19 R3

This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data