## **Gardner**

## COMPRESSOR DATA SHEET

## Federal Uniform Test Method for Certain Air Compressors Not Applicable Compressor: Variable Frequency Drive

	Rotary Compressor: Variable F MODEL DATA - FOR COMP	
1	Manufacturer: Gardner Denver	
	Model Number TVS200-W155 (NA-IP23)	Date: June 2024
2	Air-cooled X Water-cooled	Type: Screw
	Oil Injected X Oil-Free	# of Stages: 2
3*	Full Load Operating Pressure <sup>b</sup>	100 psig <sup>b</sup>
4	Drive Motor Nominal Rating	268 hp
5	Drive Motor Nominal Efficiency	95.2% percent
6	Fan Motor Nominal Rating (if applicable)	2.4 hp
7	Fan Motor Nominal Efficiency	82.5% percent
	Input Power (kW)	Capacity (acfm) a.d Specific Power (kW/10 acfm) d
	211.1	Max 1253 16.85
	182.1	1094 16.64
8*	155.3	932 16.66
	130.2	766 17.00
	106.7	598 17.84
	84.2	Min 427 19.71
9*	Total Package Input Power at Zero Flow <sup>c, d</sup>	<b>0.0</b> kW
	35.00	
	30.00	
	ACFM 725.00	
10	(KW/100ACFM)  Specific Power  20.00  20.00	
	15.00	
	10.00 0 200 400 600 800 100	00 1200 1400 1600 1800 2000
	Capacity (	(ACFM)
	Note: Graph is only a visual representa Note: Y-axis scale 10 to 35, +5kW/100acfm X-Axis Scale, 0 to 25% over r	increments if necessary above 35

<sup>\*</sup> For models that are tested in the CAGI Performance verification Program, these items are verified by program administrator

Consult CAGI website for a list of participants in the third party verification program:

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- $b. \ \ The operating \ pressure \ at \ which \ the \ Capacity \ and \ Electrical \ Consumption \ were \ measured \ for \ this \ data \ sheet.$
- C. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1% manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document

TOTAL THE terms power and energy are symonymous for purposes of any document							
Volume : at specified	flow rate I conditions	Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power			
m³/min	ft <sup>3</sup> /min	%	%				
Below 0.5	Below 17.6	+/-7	+/-8				
0.5 to 1.5	17.6 to 53	+/-6	+/-7	+/- 10%			
1.5 to 15	53 to 529.7	+/-5	+/-6				
Above 15	Above 529.7	+/-4	+/-5				

Member

ROT 031.2

12/19 R3

This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data