Gardner

COMPRESSOR DATA SHEET

Federal Uniform Test Method for Certain Air Compressors Not Applicable Compressors Variable Frequency Drive

	Rotary Compressor: Variable F MODEL DATA - FOR COMP		
1	Manufacturer: Gardner Denver		
	Model Number TVS250-W155 (NA-IP55)	Date	June 2024
2	Air-cooled X Water-cooled	Туре	Screw
	Oil Injected X Oil-Free	# of Stages:	2
3*	Full Load Operating Pressure ^b	150	psig ^b
4	Drive Motor Nominal Rating	335	hp
5	Drive Motor Nominal Efficiency	96.1%	percent
6	Fan Motor Nominal Rating (if applicable)	2.4	hp
7	Fan Motor Nominal Efficiency	82.5%	percent
	Input Power (kW)	Capacity (acfm) a,d	Specific Power (kW/100 acfm) ^d
	271.5	Max 1346	20.17
	236.2	1175	20.10
8*	202.8	999	20.30
	171.3	819	20.91
	141.0	635	22.21
	111.8	Min 448	24.98
9*	Total Package Input Power at Zero Flow ^{c, d}	0.0	kW
	35.00		
	30.00		
	ACEM) 25.00		
10	(kW/1004CEM) 25.00 (kW/1004CEM) 20.00		
	15.00		
	10.00 0 200 400 600 800 100		0 1800 2000
	Capacity (
	Note: Graph is only a visual representa Note: Y-axis scale 10 to 35, +5kW/100acfm X-Axis Scale, 0 to 25% over r	ncrements if necessary above 3	5

^{*} For models that are tested in the CAGI Performance verification Program, these items are verified by program administrator

Consult CAGI website for a list of participants in the third party verification program:

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
 - b. The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet.
 - c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1% manufacturer may state "not significant" or "0" on the test report.
 - d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document

11012. The terms power and energy are synonymous for purposes of any accument							
Volume flow rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power			
m³/min	ft ³ /min	%	%				
Below 0.5	Below 17.6	+/-7	+/-8				
0.5 to 1.5	17.6 to 53	+/-6	+/-7	+/- 10%			
1.5 to 15	53 to 529.7	+/-5	+/-6				
Above 15	Above 529.7	+/-4	+/-5				

Member

ROT 031.2

12/19 R3 This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data