Gardner

COMPRESSOR DATA SHEET

Federal Uniform Test Method for Certain Air Compressors Not Applicable Compressors Variable Frequency Drive

							ble Frequ						
1	Manufac	turer: Ga	rdner Der	iver									
	Model Number TVS250-A155 (NA-IP55)								Date:			June 2024	
2	X Air-cooled Water-cooled								Type:			Screw	
	Oil Injected X Oil-Free								# of Stages:			2	
3*	Full Load	d Operati	ng Pressu	re ^b			100			psig ^b			
4	Drive M	ıg	335			hp							
5	Drive Motor Nominal Efficiency								96.1%			percent	
6	Fan Motor Nominal Rating (if applicable)								20.1			hp	
7	Fan Motor Nominal Efficiency							92.1%			percent		
	Input Power (kW)							Capacity (acfm) a,d		n) ^{a,d}	Specific Power (kW/10 acfm) ^d		
	266.2 Max								1493			17.83	
	223.7								1295		17.28		
8*	185.2							1089			17.01		
	150.1							877		17.11			
	117.7								660		17.84		
	87.5 Min								438			19.98	
9*	Total Package Input Power at Zero Flow ^{c, d}							0.0 k			kW		
	:	35.00											
	30.00												
	Power ACFM)	25.00											
10	Specific Power (kW/100ACFM)	20.00											
		15.00											
		10.00	200	400	600	800	1000	1200	1400	1600	1800	2000	
			acity (ACF										
	Note: Graph is only a visual representation of the data in section 8 Note: Y-axis scale 10 to 35, +5kW/100acfm increments if necessary above 35 X-Axis Scale, 0 to 25% over maximum capacity												

^{*} For models that are tested in the CAGI Performance verification Program, these items are verified by program administrator

Consult CAGI website for a list of participants in the third party verification program:

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
 - $b. \ \ The \ operating \ pressure \ at \ which \ the \ Capacity \ and \ Electrical \ Consumption \ were \ measured \ for \ this \ data \ sheet.$
 - c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1% manufacturer may state "not significant" or "0" on the test report.
 - d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "nower" and "energy" are synonymous for purposes of this document

NOTE. The terms power and energy are synonymous for purposes of this document										
Volume : at specified	flow rate conditions	Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power						
m ³ /min	ft ³ /min	%	%							
Below 0.5	Below 17.6	+/-7	+/-8							
0.5 to 1.5	17.6 to 53	+/-6	+/-7	+/- 10%						
1.5 to 15	53 to 529.7	+/-5	+/-6							
Above 15	Above 529.7	+/-4	+/-5							

Member

ROT 031.2

12/19 R3

This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data