COMPRESSOR DATA SHEET



In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

1	Manufacturer:	Gard	lner Denve	er						
	Model Number			Date:		11/08/22				
2	Air-co			Type:		Screw				
							# of Stages:		1	
3*	Full Load Operating Pressure ^b				1	90			psig ^b	
4	Drive Motor Nominal Rating				1	50		hp		
5	Drive Motor Nominal Efficiency				9	5.8		percent		
6	Fan Motor Nominal Rating (if applicable)				0	.9		hp		
7	Fan Motor Noi	Fan Motor Nominal Efficiency				2.0		percent		
	Input Power (kW)				Capacity	(acfm) ^{a,d}		Specific Power (kW/100 acfm) ^d		
	138.22				1.5	(kW/1 23.77		actm)		
	117.76					4.2	23.83			
8*	97.33					5.7		23.99		
	77.68				31	4.9		24.67		
	59.04				21	9.7		26.88		
	57.39				21	0.8	27.22			
9*	Total Package Input Power at Zero Flow c, d			1	2.0		kW			
10	Isentropic Efficiency				76	5.20	%			
11	Specific Power (KW/100 A.CF.M)	35.00 30.00 25.00 20.00 15.00								
	Note: Graph is only a visi Note: Y-Axis Scale, 10 to 35, +				300.0 Capacity (ACFM ual representat - 5kW/100acfm i 0 to 25% over ma	ion of the data in a ncrements if neces	500.0 Section 8 sary above 35	600.0	700.0	



Member

ROT 031.1

a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.

b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.

c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

	olume Flow Rate	Volume Flow Rate	Specific Energy Consumption	Zero Flow Power	
m^3 / min	$\underline{ft^3} / \underline{min}$	%	%	%	
Below 0.5	Below 17.6	+/- 7	+/- 8		
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%	
1.5 to 15	53 to 529.7	+/- 5	+/- 6		
Above 15	Above 529.7	+/- 4	+/- 5		

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.