Gardner

COMPRESSOR DATA SHEET

Federal Uniform Test Method for Certain Air Compressors Not Applicable

							ble Freq OMPRE						
1	Manufa	cturer: Ga											
	Model 1	Number	TV	S200-W	155 (NA	-IP23)				Date:	Ju	ne 2024	
2	Air-cooled X Water-cooled								Type:		Screw		
	Oil Injected X Oil-Free								# of Stages:		2		
3*	Full Lo	ad Operati	ng Pressu	ıre ^b		115			psig ^b				
4	Drive M	rive Motor Nominal Rating									hp		
5	Drive Motor Nominal Efficiency								95.2%			percent	
6	Fan Motor Nominal Rating (if applicable)								2.4			hp	
7	Fan Motor Nominal Efficiency								82.5%			percent	
	Input Power (kW)							Capacity (acfm) a,d		n) a,d S	Specific Power (kW/acfm) ^d		
	218.4 Max								1222		17.87		
	189.7							1069			17.75		
8*	163.0							912			17.87		
	137.9							752			18.33		
	114.0							589		1	19.34		
	91.2 Min							1	425	5 21.46		21.46	
9*	Total Package Input Power at Zero Flow ^{c, d}							0.0 kW			kW		
		35.00											
	30.00												
	Power ACFM)	25.00											
10	Specific Power (kW/100ACFM)	20.00											
		15.00											
		10.00	-	-		-	-	-	-	-			
		0	200	400	600	800 Cov	1000	1200 EMD	1400	1600	1800	2000	
	Capacity (ACFM) Note: Graph is only a visual representation of the data in section 8												

^{*} For models that are tested in the CAGI Performance verification Program, these items are verified by program administrator

Consult CAGI website for a list of participants in the third party verification program:

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
 - $b. \ \ The \ operating \ pressure \ at \ which \ the \ Capacity \ and \ Electrical \ Consumption \ were \ measured \ for \ this \ data \ sheet.$
 - c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1% manufacturer may state "not significant" or "0" on the test report.
 - d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "nower" and "energy" are synonymous for purposes of this document

NOTE. The terms power	and energy are sync	mymous for purposes of this de	Current	
Volume : at specified	flow rate conditions	Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
m ³ /min	ft ³ /min	%	%	
Below 0.5	Below 17.6	+/-7	+/-8	
0.5 to 1.5	17.6 to 53	+/-6	+/-7	+/- 10%
1.5 to 15	53 to 529.7	+/-5	+/-6	
Above 15	Above 529.7	+/-4	+/-5	

Member

ROT 031.2

12/19 R3

This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data