Gardner Denver

COMPRESSOR DATA SHEET

Federal Uniform Test Method for Certain Air Compressors Not Applicable **Rotary Compressor: Variable Frequency Drive**

MODEL DATA - FOR COMPRESSED AIR Manufacturer: Gardner Denver **PureAir TVS110** Model Number Date June 2024 Water-cooled X Air-cooled Type 2 Screw Oil-Free Oil Injected # of Stages 2 3* Full Load Operating Pressure^b 100 psigb 4 Drive Motor Nominal Rating 150 hp 5 Drive Motor Nominal Efficiency 94.9% percent Fan Motor Nominal Rating (if applicable) 10.1 6 hp Fan Motor Nominal Efficiency 92.1% percent Specific Power Input Power (kW) Capacity (acfm) a,d (kW/100 acfm)^d 121.9 Max 685 17.80 105.8 601 17.59 8* 90.3 516 17.49 429 75.4 17.57 341 17.99 61.3 47.8 251 19.06 0.0 kW Total Package Input Power at Zero Flow^{c, d} 30 25 Specific Power (kW/100ACFM) 10 10 400 600 800 1000 1200 Capacity (ACFM) Note: Graph is only a visual representation of the data in section 8

* For models that are tested in the CAGI Performance verification Program, these items are verified by program administrator

Consult CAGI website for a list of participants in the third party verification program: NOTES

www.cagi.org

a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; acfm is actual cubic feet per minute at inlet conditions.

Note: Y-axis scale 10 to 35, +5kW/100acfm increments if necessary above 35 X-Axis Scale, 0 to 25% over maximum capacity

- $b. \ \ The operating \ pressure \ at \ which \ the \ Capacity \ and \ Electrical \ Consumption \ were \ measured \ for \ this \ data \ sheet.$
- $^{\text{C.}}$ No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1% manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document

Volume flow rate Specific Energy No Load / Zero Flow Consumption at specified conditions Volume Flow Rate Power m³/min Below 0.5 Below 17.6 +/-8 0.5 to 1.5 17.6 to 53 +/-6 +/-7 +/- 10% 53 to 529.7 1.5 to 15 +/-5 +/-6 Above 15 Above 529.7 +/-4

Member:

Member:

ROT 031.2

This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data