<u>Gardner</u>

COMPRESSOR DATA SHEET

Federal Uniform Test Method for Certain Air Compressors Not Applicable Compressor: Variable Frequency Drive

	Rotary Compressor: Varial MODEL DATA - FOR CO		•	
1	Manufacturer: Gardner Denver		-	
	Model Number TVS315-W155 (NA-IP55)		Date:	June 2024
2	Air-cooled X Water-cooled	Type:	Screw	
	Oil Injected X Oil-Free		# of Stages:	2
3*	Full Load Operating Pressure ^b	125	psig ^b	
4	Drive Motor Nominal Rating	422	hp	
5	Drive Motor Nominal Efficiency	95.9%	percent	
6	Fan Motor Nominal Rating (if applicable)	2.4	hp	
7	Fan Motor Nominal Efficiency	82.5%	percent	
	Input Power (kW)	Capacity (acfm) a,d	Specific Power (kW/10) acfm) ^d	
	339.7	Max	1744	19.48
	285.4		1521	18.76
8*	236.0		1287	18.33
	190.7		1044	18.27
	149.0		792	18.82
	110.2	532	20.70	
9*	Total Package Input Power at Zero Flow ^{c, d}	0.0	kW	
	35.00			
	30.00			
	ACFM) ACFM)			
10	25.00			
	15.00			
	10.00 0 200 400 600 800	1000	1200 1400 1600 M)	0 1800 2000
	Note: Graph is only a visual repr Note: Y-axis scale 10 to 35, +5kW/100 X-Axis Scale, 0 to 25%	Oacfm incre	of the data in section 8 ments if necessary above 3:	5

^{*} For models that are tested in the CAGI Performance verification Program, these items are verified by program administrator

Consult CAGI website for a list of participants in the third party verification program:

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
 - b. The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet.
 - C. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1% manufacturer may state "not significant" or "0" on the test report.
 - d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document

1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1								
Volume flow rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power				
m ³ /min	ft ³ /min	%	%					
Below 0.5	Below 17.6	+/-7	+/-8					
0.5 to 1.5	17.6 to 53	+/-6	+/-7	+/- 10%				
1.5 to 15	53 to 529.7	+/-5	+/-6					
Above 15	Above 529.7	+/-4	+/-5					

Member

ROT 031.2

12/19 R3 This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data