## **Gardner**

## COMPRESSOR DATA SHEET

Federal Uniform Test Method for Certain Air Compressors Not Applicable

Compressors Variable Frequency Drive

	Rotary Compressor: Variable F MODEL DATA - FOR COMP					
1	Manufacturer: Gardner Denver					
	Model Number TVS250-A155 (NA-IP23)	Date	June 2024			
2	X Air-cooled Water-cooled	Туре	Screw			
	Oil Injected X Oil-Free	# of Stages	2			
3*	Full Load Operating Pressure <sup>b</sup>	125	psig <sup>b</sup>			
4	Drive Motor Nominal Rating	335	hp			
5	Drive Motor Nominal Efficiency	95.6%	percent			
6	Fan Motor Nominal Rating (if applicable)	20.1	hp			
7	Fan Motor Nominal Efficiency	92.1%	percent			
	Input Power (kW)	Capacity (acfm) a,d	Specific Power (kW/10 acfm) <sup>d</sup>			
	267.9	Max 1386	19.32			
	229.5	1206	19.04			
8*	193.9	1020	19.02			
	160.6	828	19.39			
	129.3	633	20.44			
	99.7	Min 434	22.99			
9*	Total Package Input Power at Zero Flow <sup>c, d</sup>	0.0	kW			
	35.00					
	Specific Power (kW/100ACFM) 25.00 20.00					
10	Specific (RW/100					
	15.00					
	10.00 0 200 400 600 800 100  Capacity (		0 1800 2000			
	Note: Graph is only a visual representation of the data in section 8  Note: Y-axis scale 10 to 35, +5kW/100acfm increments if necessary above 35  X-Axis Scale, 0 to 25% over maximum capacity					

<sup>\*</sup> For models that are tested in the CAGI Performance verification Program, these items are verified by program administrator

Consult CAGI website for a list of participants in the third party verification program:

a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.

- $b. \ \ The \ operating \ pressure \ at \ which \ the \ Capacity \ and \ Electrical \ Consumption \ were \ measured \ for \ this \ data \ sheet.$
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1% manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "nower" and "energy" are synonymous for purposes of this document

NOTE. The terms power and energy are synonymous for purposes of this document							
Volume flow rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power			
m <sup>3</sup> /min	ft <sup>3</sup> /min	%	%				
Below 0.5	Below 17.6	+/-7	+/-8				
0.5 to 1.5	17.6 to 53	+/-6	+/-7	+/- 10%			
1.5 to 15	53 to 529.7	+/-5	+/-6				
Above 15	Above 529.7	+/-4	+/-5				

Member

ROT 031.2

12/19 R3

This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data