Gardner

COMPRESSOR DATA SHEET

Federal Uniform Test Method for Certain Air Compressors Not Applicable Compressors Variable Frequency Drive

								ompres							
1	Manufa	acturer	: Gardn	er Der	iver										
	Model Number TVS315-A155 (NA-IP55)									Date:			June 2024		
2	X Air-cooled Water-cooled									Туре:			Screw		
	Oil Injected X Oil-Free									# of Stages:			2		
3*	Full Lo	oad Operating Pressure ^b								150			psig ^b		
4	Drive Motor Nominal Rating								422			hp			
5	Drive Motor Nominal Efficiency								95.9%			percent			
6	Fan Motor Nominal Rating (if applicable)								20.1			hp			
7	Fan Motor Nominal Efficiency							92.1%			percent				
	Input Power (kW)									Capacity (acfm) a,d		Specific Power (kW acfm) ^d		kW/10	
			338	3.5		1570			21.56						
	288.3									1372		21.01			
8*	242.2								1166		20.76				
	199.6								954		20.93				
	160.1									735		21.78			
	123.1 Min									510		24.11			
9*	Total Package Input Power at Zero Flow ^{c, d}						0.0			kW					
	r C	35.00 30.00												-	
10	Specific Power (kW/100ACFM)	25.00										-			
		20.00												-	
		15.00													
		10.00	0	200	400	600	800	1000	1200	1400	1600	1800	2000	-	
	Capacity (ACFM)														
	Note: Graph is only a visual representation of the data in section 8 Note: Y-axis scale 10 to 35, +5kW/100acfm increments if necessary above 35 X-Axis Scale, 0 to 25% over maximum capacity														

^{*} For models that are tested in the CAGI Performance verification Program, these items are verified by program administrator

Consult CAGI website for a list of participants in the third party verification program:

www.cagi.org

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
 - b. The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet.
 - c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1% manufacturer may state "not significant" or "0" on the test report.
 - d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document

110 12. The terms power and energy are symonymous for purposes of this document										
Volume : at specified	flow rate I conditions	Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power						
m ³ /min	ft ³ /min	%	%							
Below 0.5	Below 17.6	+/-7	+/-8							
0.5 to 1.5	17.6 to 53	+/-6	+/-7	+/- 10%						
1.5 to 15	53 to 529.7	+/-5	+/-6							
Above 15	Above 529.7	+/-4	+/-5							

Member

ROT 031.2

12/19 R3 This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data