Gardner

COMPRESSOR DATA SHEET

Federal Uniform Test Method for Certain Air Compressors Not Applicable Compressor: Variable Frequency Drive

	Rotary Compressor: Variable 1 MODEL DATA - FOR COM			
1	Manufacturer: Gardner Denver			
	Model Number TVS355-W155 (NA-IP55)		Date:	June 2024
2	Air-cooled X Water-cooled		Type:	Screw
	Oil Injected X Oil-Free		# of Stages:	2
3*	Full Load Operating Pressure ^b	d Operating Pressure ^b		
4	Drive Motor Nominal Rating	ominal Rating		
5	Drive Motor Nominal Efficiency	96.0%	percent	
6	Fan Motor Nominal Rating (if applicable)	2.4	hp	
7	Fan Motor Nominal Efficiency	82.5%	percent	
	Input Power (kW)		Capacity (acfm) a,d	Specific Power (kW/10) acfm) ^d
	356.8	Max	1807	19.74
	297.9		1575	18.91
8*	244.5		1330	18.39
	195.9		1073	18.25
	151.2		807	18.75
	109.9	Min	532	20.66
9*	Total Package Input Power at Zero Flow ^{c, d}		0.0	kW
	35.00			
	30.00			
	4 CEM) 4 CEM) 4 CEM)			
10	25.00 (KW/100ACFM) 20.00 (Specific Power 20.00)			
-	15.00			
	0 200 400 600 800 10	00	1200 1400 1600	0 1800 2000
	Capacity	(ACFI	M)	
	Note: Graph is only a visual represen Note: Y-axis scale 10 to 35, +5kW/100acfr X-Axis Scale, 0 to 25% over	n incren	nents if necessary above 3	5

^{*} For models that are tested in the CAGI Performance verification Program, these items are verified by program administrator

Consult CAGI website for a list of participants in the third party verification program:

+/-6

No Load / Zero Flow

Power

+/- 10%

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
 - b. The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet.
 - c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1% manufacturer may state "not significant" or "0" on the test report.

+/-5

d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

53 to 529.7

	NOTE: The terms "power" and "energy" are synonymous for purposes of this document						
Member	Volume	flow rate		Specific Energy			
	at specified conditions		Volume Flow Rate	Consumption			
	m ³ /min	ft ³ /min	%	%			
	Below 0.5	Below 17.6	+/-7	+/-8			
	0.5 to 1.5	17.6 to 53	+/-6	+/-7			

ROT 031.2

12/19 R3 This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data

1.5 to 15

Above 15