Gardner

COMPRESSOR DATA SHEET

Federal Uniform Test Method for Certain Air Compressors Not Applicable

	Rotary Compressor: Variable Fre MODEL DATA - FOR COMPR					
1	Manufacturer: Gardner Denver					
	Model Number TVS250-W155 (NA-IP55)	Date	June 2024			
2	Air-cooled X Water-cooled	Туре	Screw			
	Oil Injected X Oil-Free	# of Stages:	2			
3*	Full Load Operating Pressure ^b	100	psig ^b			
4	Drive Motor Nominal Rating	335	hp			
5	Drive Motor Nominal Efficiency	96.1%	percent			
6	Fan Motor Nominal Rating (if applicable)	2.4	hp			
7	Fan Motor Nominal Efficiency	82.5%	percent			
	Input Power (kW)	Capacity (acfm) a,d	Specific Power (kW/10) acfm) ^d			
	262.4 M	1527	17.18			
	221.8	1326	16.72			
8*	184.6	1117	16.52			
	150.3	902	16.66			
	118.4	681	17.38			
	88.4 M	in 455	19.40			
9*	Total Package Input Power at Zero Flow ^{c, d}	0.0	kW			
	35.00					
	30.00					
	Specific Power (kW/100ACFM) 25.00 Specific Power (kW/100ACFM) 20.00 Specific					
10	Specific (KW/100) 20.00					
	15.00					
	10.00 0 200 400 600 800 1000 Connector (A	1200 1400 1600	0 1800 2000			
	Capacity (ACFM) Note: Graph is only a visual representation of the data in section 8					
	Capacity (A	CFM) n of the data in section 8 rements if necessary above 3.				

^{*} For models that are tested in the CAGI Performance verification Program, these items are verified by program administrator

Consult CAGI website for a list of participants in the third party verification program:

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
 - $b. \ \ The operating \ pressure \ at \ which \ the \ Capacity \ and \ Electrical \ Consumption \ were \ measured \ for \ this \ data \ sheet.$
 - C. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1% manufacturer may state "not significant" or "0" on the test report.
 - d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document

11012. The terms power and energy are synonymous for purposes of any accument							
Volume flow rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power			
m ³ /min	ft ³ /min	%	%				
Below 0.5	Below 17.6	+/-7	+/-8				
0.5 to 1.5	17.6 to 53	+/-6	+/-7	+/- 10%			
1.5 to 15	53 to 529.7	+/-5	+/-6				
Above 15	Above 529.7	+/-4	+/-5				

Member

ROT 031.2

12/19 R3 This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data