## Gardner

## COMPRESSOR DATA SHEET

Percent Uniform Test Method for Certain Air Compressors Not Applicable MODEL DATA - FOR COMPRESSED AIR Manufacturer: Gardner Denver 1 Model Number TVS250-A155 (NA-IP55) Date: June 2024 Water-cooled 2 X Air-cooled Type Screw X Oil-Free # of Stages Oil Injected 2 3\* Full Load Operating Pressure<sup>b</sup> 150 psig<sup>b</sup> 4 Drive Motor Nominal Rating 335 hp 5 Drive Motor Nominal Efficiency 96.1% percent 6 Fan Motor Nominal Rating (if applicable) 20.1 hp 7 Fan Motor Nominal Efficiency 92.1% percent Specific Power (kW/100 Capacity (acfm) a,d Input Power (kW) acfm) 1282 20.80 266.5 Max 231.9 1119 20.73 8\* 199.4 952 20.95 168.7 781 21.61 139.5 607 23.00 111.4 Min 429 25.97 9\* 0.0 kWTotal Package Input Power at Zero Flow<sup>c, d</sup> 35.00 30.00 Specific Power (kW/100ACFM) 20.00 10 15.00 10.00 2000 200 400 600 800 1000 1200 1400 1600 1800

\* For models that are tested in the CAGI Performance verification Program, these items are verified by program administrator

Consult CAGI website for a list of participants in the third party verification program:

a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.

Capacity (ACFM) Note: Graph is only a visual representation of the data in section  $\boldsymbol{8}$ Note: Y-axis scale 10 to 35, +5kW/100acfm increments if necessary above 35 X-Axis Scale, 0 to 25% over maximum capacity

- $b. \ \ The operating \ pressure \ at \ which \ the \ Capacity \ and \ Electrical \ Consumption \ were \ measured \ for \ this \ data \ sheet.$
- $^{\text{C.}}$  No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1% manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document

Volume flow rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
m <sup>3</sup> /min	ft <sup>3</sup> /min	%	%	
Below 0.5	Below 17.6	+/-7	+/-8	
0.5 to 1.5	17.6 to 53	+/-6	+/-7	+/- 10%
1.5 to 15	53 to 529.7	+/-5	+/-6	
Above 15	Above 529.7	+/-4	+/-5	

Member

ROT 031.2

12/19 R3

This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data