Gardner

Denver
Federal Uniform Test Method for Certain Air Compressors Not Applicable
Compressor: Variable Frequency Drive

MODEL DATA - FOR COMPRESSED AIR			
1	Manufacturer: Gardner Denver		
	Model Number PureAir TVS110	Date:	June 2024
2	Air-cooled X Water-cooled	Type:	Screw
	Oil Injected X Oil-Free	# of Stages:	2
3*	Full Load Operating Pressure ^b	100	psig ^b
4	Drive Motor Nominal Rating	150	hp
5	Drive Motor Nominal Efficiency	94.9%	percent
6	Fan Motor Nominal Rating (if applicable)	1.2	hp
7	Fan Motor Nominal Efficiency	82.5%	percent
8*	Input Power (kW)	Capacity (acfm) a,d	Specific Power (kW/100 acfm) ^d
	120.2 Max	685	17.54
	104.7	602	17.40
	89.7	516	17.37
	75.3	429	17.53
	61.5	341	18.03
	48.3 Min	251	19.22
9*	Total Package Input Power at Zero Flow ^{c, d}	0.0	kW
10	30 25 (km/1000 CEW) 20 15 15 10 0 200 400 600	800	1000 1200
	Capacity (ACFM)	555	
<u> </u>	Note: Graph is only a visual representation of the data in section 8 Note: Y-axis scale 10 to 35, +5kW/100acfm increments if necessary above 35 X-Axis Scale, 0 to 25% over maximum capacity		

* For models that are tested in the CAGI Performance verification Program, these items are verified by program administrator

Consult CAGI website for a list of participants in the third party verification program:

www.cagi.org

a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; acfm is actual cubic feet per minute at inlet conditions.

- $b. \ \ The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet.$
- $^{\text{C.}}$ No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1% manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document

Specific Energy Consumption No Load / Zero Flow Power at specified conditions Volume Flow Rate m³/min Below 0.5 Below 17.6 0.5 to 1.5 17.6 to 53 +/-6 +/-7 +/- 10% 1.5 to 15 53 to 529.7 +/-5 +/-6 Above 15 Above 529.7

Member:

Member:

ROT 031.2

This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data