## **Gardner**

## COMPRESSOR DATA SHEET

## Federal Uniform Test Method for Certain Air Compressors Not Applicable

							ompres						
1	Manufa	acturer: Ga	ardner Der	iver									
	Model Number TVS315-W155 (NA-IP23)								Date:			June 2024	
2	Air-cooled X Water-cooled								Type:		Screw		
	Oil Injected X Oil-Free								# of Stages:			2	
3*	Full Lo	ull Load Operating Pressure <sup>b</sup>								125			
4	Drive Motor Nominal Rating								422			hp	
5	Drive Motor Nominal Efficiency							95.5%			percent		
6	Fan Motor Nominal Rating (if applicable)							2.4			hp		
7	Fan Motor Nominal Efficiency							<b>82.5%</b> perce			ercent		
	Input Power (kW)								city (acfr	n) <sup>a,d</sup>	Specific Power (kV acfm) <sup>d</sup>		100
	341.3 Max								1744			19.58	
	287.1								1521		18.88		
8*	237.7							1287			18.46		
			192.3					1044			18.42		
	150.3								792 1		18.99		
	<b>111.2</b> Mir							532 20		20.90			
9*	Total Package Input Power at Zero Flow <sup>c, d</sup>								<b>0.0</b> kW		kW		
		35.00											
		30.00											
	Power ACFM)	25.00											
10	Specific Power (kW/100ACFM)	20.00			_								
		15.00											
		10.00	200	400	600	800	1000	1200	1400	1600	1800	2000	
				acity (ACI									
	Note: Graph is only a visual representation of the data in section 8  Note: Y-axis scale 10 to 35, +5kW/100acfm increments if necessary above 35  X-Axis Scale, 0 to 25% over maximum capacity												

<sup>\*</sup> For models that are tested in the CAGI Performance verification Program, these items are verified by program administrator

Consult CAGI website for a list of participants in the third party verification program:

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1% manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document

	e flow rate d conditions	Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power						
m <sup>3</sup> /min	ft <sup>3</sup> /min	%	%							
Below 0.5	Below 17.6	+/-7	+/-8							
0.5 to 1.5	17.6 to 53	+/-6	+/-7	+/- 10%						
1.5 to 15	53 to 529.7	+/-5	+/-6							
Above 15	Above 529.7	+/-4	+/-5							

Member

ROT 031.2

12/19 R3 This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data