## **Gardner**

## COMPRESSOR DATA SHEET

Federal Uniform Test Method for Certain Air Compressors Not Applicable

			FOR COMPRES					
1	Manufacturer: Gardner D	enver						
	Model Number T	VS315-A155 (NA-	-IP55)	Date	June 2024			
2	X Air-cooled Water-cooled			Туре	Screw			
	Oil Injected X Oil-Free			# of Stages	: 2			
3*	Full Load Operating Press	Operating Pressure <sup>b</sup>			psig <sup>b</sup>			
4	Drive Motor Nominal Rat	tor Nominal Rating			hp			
5	Drive Motor Nominal Eff	rive Motor Nominal Efficiency			percent			
6	Fan Motor Nominal Rating (if applicable)			20.1	hp			
7	Fan Motor Nominal Effic	ency	92.1%	percent				
	Input Power (kW)			Capacity (acfm) a,d	Specific Power (kW/acfm) <sup>d</sup>			
	339.4 Max			1778	19.09			
	279.2			1548	18.04			
8*	225.8			1305	17.30			
	178.2			1052	16.94			
	135.5			789	17.17			
	96.9			518	18.70			
9*	Total Package Input Power at Zero Flow <sup>c, d</sup>			0.0	kW			
	35.00							
	30.00							
	25.00 Power 25.00							
10	Specific Power (kW/100A CFM)  20.00							
	15.00							
	10.00 0 200	400 600	800 1000	1200 1400 160	0 1800 2000			
	Capacity (ACFM)  Note: Graph is only a visual representation of the data in section 8							
	1	Note: Graph is only a: Y-axis scale 10 to 35.	Capacity (ACF visual representation	M) of the data in section 8 ments if necessary above 3				

<sup>\*</sup> For models that are tested in the CAGI Performance verification Program, these items are verified by program administrator

Consult CAGI website for a list of participants in the third party verification program:

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
  - $b. \ \ The \ operating \ pressure \ at \ which \ the \ Capacity \ and \ Electrical \ Consumption \ were \ measured \ for \ this \ data \ sheet.$
  - c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1% manufacturer may state "not significant" or "0" on the test report.
  - d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document

Volume flow rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
m <sup>3</sup> /min	ft <sup>3</sup> /min	%	%	
Below 0.5	Below 17.6	+/-7	+/-8	
0.5 to 1.5	17.6 to 53	+/-6	+/-7	+/- 10%
1.5 to 15	53 to 529.7	+/-5	+/-6	
Above 15	Above 529.7	+/-4	+/-5	

Member

ROT 031.2

12/19 R3

This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data